

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7320-0476:137

Page 1 of 2

CATEGORY: Speakers

LISTEE: Harrington Signal Inc., 2519 4th Avenue, Moline, IL 61265
Contact: Andrew Keller (309) 762-0731

DESIGN: Models 4"LPSPKF025VWR, 4"LPSPKF070VWR, 4"LPSPKF025VWW, 4"LPSPKF070VWW (wall mounted), 8"LPSPKF025VCW, 8"LPSPKF070VCW (ceiling mounted) speakers.

Models 4"LPSPK015/75-25VWR, -70VWR, -25VWW, -70VWW; 4"LPSPK030/75-25VWR, -70VWR, -25VWW, -70VWW; 4"LPSPK060/75-25VWR, -70VWR, -25VWW, -70VWW; 4"LPSPK075-25VWR, -70VWR, -25VWW, -70VWW; 4"LPSPK0110-25VWR, -70VWR, -25VWW, -70VWW; 4"LPSPK015/75-25VWRS, -70VWRS, -25VWWS, -70VWWS; 4"LPSPK030/75-25VWRS, -70VWRS, -25VWWS, -70VWWS; 4"LPSPK060/75-25VWRS, -70VWRS, -25VWWS, -70VWWS; 4"LPSPK075-25VWRS, -70VWRS, -25VWWS, -70VWWS; 4"LPSPK0110-25VWRS, -70VWRS, -25VWWS, -70VWWS (wall mounted) speaker strobes.

Models 8"LPSPKF015/75-25VCW, -70VCW; 8"LPSPKF030/75-25VCW, -70VCW; 8"LPSPKF060/75-25VCW, -70VCW; 8"LPSPKF075-25VCW, -70VCW; 8"LPSPKF0110-25VCW, -70VCW; 8"LPSPKF015/75-25VCWS, -70VCWS; 8"LPSPKF030/75-25VCWS, -70VCWS; 8"LPSPKF060/75-25VCWS, -70VCWS; 8"LPSPKF075-25VCWS, -70VCWS; 8"LPSPKF0110-25VCWS, -70VCWS (ceiling mounted) speaker strobes.

Units are cone type speaker assembly which are available in 25 V rms and 70.7 V rms versions. The wattage taps available at 1/4W, 1/2W, 1W and 2W. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 25 Vrms and 70.7 Vrms
Candela: 15 cd; 30 cd, 60 cd, 75 cd; 110 cd

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical, candela, audibility rating, and UL label.

APPROVAL: Listed as speakers and speaker/strobes for use with separately listed compatible fire alarm control units. For indoor use only. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition is required, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to listee's Installation Instructions Manual for details.

XLF: 7320-0065:156

04-14-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 9, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager